

**DELHI DEVELOPMENT AUTHORITY  
EMI'S OFFICE**

Oct. 8/28 1993

50- E M I C I 83 / 16,805  
CIRCULAR NO. E 65.

During the inspection of CTE of the work of DDA, it was observed that Acrylic based water proofing compound of Max Corona make was used. The sample of this Acrylic based water proofing compound was sent tested by CTE from National Test House, Calcutta. The test report received by CTE indicates that there was no presence of Acrylic based water proofing compound in the sample. CTE has further clarified that no firm in India is manufacturing Acrylic based water proofing compound.

Henceforth, the stipulation of Acrylic based water proofing compound may be dis-continued and only ordinary cement based water proofing compound may be used. In all the cases where Acrylic based water proofing compound has been used in DDA works, recoveries may be affected from the contractor's bills. The copy of the recovery statement supported by the analysis of rates be sent to CTE wherever necessary.

~~( U.S. MARINE )~~  
ENGINEER MEMBER

**Copy to:**

1. All CE's DDA for information and necessary action along with 20 spare copies for circulation among their SE's (Plg.) & EE.
  2. Director (Hort) North & South DDA.
  3. CE (QC), DDA.
  4. G.M., ISBT, DDA.
  5. Director (newly)
  - (a) All EC's and M's  
of EM office

~~ALL INFORMATION CONTAINED~~ E.O.I to C.M.  
~~HEREIN~~ D.D.A.